



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2024/B/5760195  
Dated/दिनांक : 29-12-2024

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	20-01-2025 12:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	20-01-2025 12:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	30 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Electronics And Information Technology
Department Name/विभाग का नाम	Department Of Electronics And Information Technology
Organisation Name/संगठन का नाम	Centre For Materials For Electronics Technology (cmet)
Office Name/कार्यालय का नाम	Cmetpune
क्रेता ईमेल/Buyer Email	ranjit.kashid@cmet.gov.in
Total Quantity/कुल मात्रा	1
Item Category/मद केटेगरी	Online UPS (V2) (Q2)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	3 Year (s)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Certificate (Requested in ATC),OEM Authorization Certificate,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	No
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid

**Bid Details/बिड विवरण**

<b>Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय</b>	2 Days
<b>Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>Evaluation Method/मूल्यांकन पद्धति</b>	Total value wise evaluation
<b>Arbitration Clause</b>	No
<b>Mediation Clause</b>	No

**EMD Detail/ईएमडी विवरण**

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	75000

**ePBG Detail/ईपीबीजी विवरण**

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	15

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

**Beneficiary/लाभार्थी :**

Director

CMETPUNE, Department of Electronics and Information Technology, Centre for Materials for Electronics Technology (CMET), Ministry of Electronics and Information Technology  
(Centre For Materials For Electronics Technology C-met)**UIN Number NCTGC2415P****MII Purchase Preference/एमआईआई खरीद वरीयता**

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

**MSE Purchase Preference/एमएसई खरीद वरीयता**

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

**Pre Bid Detail(s)**

Pre-Bid Date and Time	Pre-Bid Venue
07-01-2025 10:00:00	Centre for Materials for Electronics Technology (C-MET), Off Pashan Rd, Panchwati Pashan, Pune-411008, Maharashtra

**Online UPS (V2) ( 1 pieces )**

**(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/कमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)**

Bis Required	Yes
--------------	-----

### Technical Specifications/तकनीकी विशिष्टियाँ

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Generic	<b>Rating in KVA</b>	80.0 KVA
	<b>Switching Technology</b>	IGBT-PWM
	<b>Input Voltage</b>	AC Three phase 300 V - 450V sinewave 50Hz
	<b>Output Voltage</b>	AC 3 phase 415V having a variable setting the range starting from 380 volt - variable upto to 415 volt.
	<b>Warranty for UPS (Years)</b>	1, 2, 3, 4, 5 Or higher
Battery/Backup Bank	<b>Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )</b>	With Battery
	<b>Type of Battery (hint: NA in case Battery not provided)</b>	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	<b>Backup time (Minutes) (hint: NA in case battery not provided)</b>	30 Minutes
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	<b>Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided</b>	2, 3 Or higher
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 24 hours, Within 48 hours, Within 7 days, NA
Performance / Functional	<b>Inbuilt isolation transformer</b>	With, Without
	<b>Overall Efficiency (%)</b>	>/=90% & <94% without Inbuilt isolation transformer
	<b>Overload limit</b>	20% Overload for minimum 10 minute, 20% Overload for minimum 5 minute, 50% Overload for minimum 1 minute, 50% Overload for minimum 3 seconds

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Other Functional Features	Noise level (1 meter distance from UPS) should be less than 70dB, Input power factor at full output load leading to unity with active power factor correction (APFC) $\geq 0.92$ , Transient response time (for 100% load change, output must remain within +/-1% and recovery) as $< 20$ milliseconds, Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours, Maximum overshoot and Under shoot of output rated voltage (in percentage) (4%), Voltage Regulation from no load to full load (%) ( $< / = 2\%$ ), UPS input power factor better than 0.95 (at rated voltage)
Accessories	<b>Accessories</b>	Rack for Batteries, SNMP Card ( with Suitable Software ) for communication, The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc
Salient Features	Protection	Protection for under voltage at battery terminal, Protection of Over voltage, Short Circuit & over load at UPS output terminal, Over temperature protection
	Metering	Input Voltage, Output Voltage, Input Frequency, Output Frequency
	Alarms and Indications	Indicator for Mains presence, Indicator for Battery charging and discharging, Indicator for Output Over Load with Audible Alarm, Indicator for Low Battery Voltage with Audible Alarm, Alarm for Over temperature, Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output
Design / Construction	<b>Type of Design / Construction</b>	Floor Standing
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP21, IP20 Or higher
	Other Constructional Features	Mains ON/OFF MCB, Battery ON/OFF MCB, Battery Fuse, Inverter reset push button, Static by pass facility, Manual by pass facility, Expandable rack facility, Shall be complete with rack rail kit for mounting of UPS in the rack and shall be housed in rugged enclosure made of steel sheet having 1.2 mm (minimum) thickness, aesthetically finished,duly pretreated and powder coated, UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional, 1 + 1 parallel redundant configuration facility on Rack mountable UPS UPS shall supply output power and charging current at the same time, NA
Operating Conditions	Relative Humidity Non Condensing at 40 deg C	90, 95 Or higher ( <b>percent</b> )

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C
	Battery Test Report	Type Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	NABL accredited lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes

#### Additional Specification Parameters - Online UPS (V2) ( 1 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Built-in or external isolation transformer. Minimum VAH 72000 or higher, endcell voltage 1.75V	Built-in or external isolation transformer. Minimum VAH 72000 or higher, endcell voltage 1.75V
Battery manuf. date within one month from DODelivery and should be of same manufacturing batch	Battery manuf. date within one month from DODelivery and should be of same manufacturing batch
Compulsory visit to C-MET before quoting cable assembly form mans to ups to ups output. Contact Dr. Kashid 8149253356 for visit	Compulsory visit to C-MET before quoting cable assembly form mans to ups to ups output. Contact Dr. Kashid 8149253356 for visit
75 m, 35sqmm multicore armoured cable of 1.1 kV grade, 4 earth pit&connection,MCB(Schnider,L &T,Simens,Legrand),cabletrays, conducts,clamps,industrysocket at o/p & i/p of ups. Quote only after onsite visit at C-MET Pune	75 m, 35sqmm multicore armoured cable of 1.1 kV grade, 4 earth pit&connection,MCB(Schnider,L&T,Simens,Legrand),cabletrays,conducts,clamps,industrysocketat o/p & i/p of ups. Quote only after onsite visit at C-MET Pune
Registered office in Pune with Service records, at least 5 delivery of same equipment for qualification,nondisctinued model,should be made with standards,RS232,LAN,SelfDignosis.	Registered office in Pune with Service records, at least 5 delivery of same equipment for qualification,nondisctinued model,should be made with standards,RS232,LAN,SelfDignosis.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ranjit Vilas Kashid	411008,panchawatti , Off Pashan Road ,Pune	1	30

**Buyer added Bid Specific Additional Scope of Work**

S.No.क्र.सं .	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
1	Technical Specifications <a href="#">View</a>	Cabling for UPS specified in Sr. 09 of this document	Online UPS (V2)(1)

**The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.**

**Special terms and conditions-Version:1 effective from 06-07-2022 for category Online UPS (V2)**

1. In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

**Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें**

**1. Generic**

After award of contract - Successful Bidder shall have to get Detailed Design Drawings approved from buyer before starting fabrication. Successful Bidder shall submit Detailed Design Drawings for Buyer's approval, within 5 days of award of contract. Buyer shall, either approve the drawings or will provide complete list of modification required in the drawings within 5 days. Seller shall be required to ensure supply as per approved Drawings with modifications as communicated by Buyer. If there is delay from buyer side in approval of drawing- the delivery period shall be refixed without LD for the period of delay in approval of Drawing.

2. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

Dr. Ranjit Kashid  
Centre for Materials for Electronics Technology  
Off Pashan Rd  
Panchwati Pune Mahastrahtra  
Pin 411008  
.

3. **Generic**

**Bidder financial standing:** The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.

4. **Generic**

Bidders shall quote only those products (Part of Service delivery) in the bid which are not obsolete in the market and has at least 3 years residual market life i.e. the offered product shall not be declared end-of-life by the OEM before this period.

5. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

6. **Generic**

**Consortium:** In case of Contracts, wherein the seller alone does not have necessary expertise, the seller can form consortium with other sellers for submission of the bid, with one of the consortium company as leader. However, each and every member of the consortium shall be equally responsible for the complete execution of the project contract. An undertaking to this effect is to be uploaded with bid.

7. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

8. **Generic**

Experience Criteria: The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for 3 years before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.

9. **Generic**

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

10. **Generic**

Malicious Code Certificate:

The seller should upload following certificate in the bid:-

(a) This is to certify that the Hardware and the Software being offered, as part of the contract, does not contain Embedded Malicious code that would activate procedures to :-



- (i) Inhibit the desires and designed function of the equipment.
  - (ii) Cause physical damage to the user or equipment during the exploitation.
  - (iii) Tap information resident or transient in the equipment/network.
- (b) The firm will be considered to be in breach of the procurement contract, in case physical damage, loss of information or infringements related to copyright and Intellectual Property Right (IPRs) are caused due to activation of any such malicious code in embedded software.

11. **Generic**

**Manufacturer Authorization:**Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

12. **Generic**

**OPTIONAL SITE VISIT:**

1. The Bidder is advised to visit and examine the installation site and its surroundings and obtain for itself on its own responsibility all information that may be necessary for preparing the Bid. The costs of visiting the site shall be borne by the Bidder.

no cost or allowance of visiting will be given by C-MET Pune. Bidder has to bare the cost.

2. The Bidder representative shall be allowed entry upon consignee premises for such visits, only upon the express conditions that the Bidder will release and indemnify the Buyer and Consignee against all liabilities arising out of such visit including death or injury, loss or damage to property, and any other loss, damage, costs, and expenses incurred as a result of such visit.

3. The Bidder shall not be entitled to hold any claim against Buyer for noncompliance due to lack of any kind of pre-requisite information as it is the sole responsibility of the Bidder to obtain all the necessary information with regard to site, surrounding, working conditions, weather etc. on its own before submission of the bid.

13. **Generic**

Scope of supply includes Training: Number of employees to be trained

02  
, Place for Training  
C-MET Pune  
and Duration of training  
1  
days.

14. **Generic**

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

15. **Generic**

- 1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
- 2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior

written consent of buyer.

3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

#### 16. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

#### 17. **OEM**

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

#### 18. **Service & Support**

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

#### 19. **Service & Support**

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

#### 20. **Warranty**

Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

### **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.

11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.**

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

**---Thank You/धन्यवाद---**