



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2024/B/5767196  
Dated/दिनांक : 07-01-2025

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	21-01-2025 12:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	21-01-2025 12:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Department Of Space
Department Name/विभाग का नाम	Department Of Space
Organisation Name/संगठन का नाम	Indian Space Research Organization
Office Name/कार्यालय का नाम	Satish Dhawan Space Centre Shar
क्रेता ईमेल/Buyer Email	con33.isro.ap@gembuyer.in
Total Quantity/कुल मात्रा	470
Item Category/मद केटेगरी	MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1) (Q2)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes
Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है	Yes
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	No
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	MCB - Miniature Circuit - Breakers for A.C. Operation as per IS / IEC 60898 (Part 1)

**Bid Details/बिड विवरण**

<b>Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय</b>	2 Days
<b>Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>Evaluation Method/मूल्यांकन पद्धति</b>	Total value wise evaluation
<b>Arbitration Clause</b>	No
<b>Mediation Clause</b>	No

**EMD Detail/ईएमडी विवरण**

Required/आवश्यकता	No
-------------------	----

**ePBG Detail/ईपीबीजी विवरण**

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	3.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	14

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

**Beneficiary/लाभार्थी :**

SENIOR ACCOUNTS OFFICER

Finance & Accounts Officer(P), Satish Dhawan Space Centre SHAR, Department of Space, indian space research organization, Department of Space  
(Senior Accounts Officer)

**MII Purchase Preference/एमआईआई खरीद वरीयता**

MII Purchase Preference/एमआईआई खरीद वरीयता	No
--	----

**MSE Purchase Preference/एमएसई खरीद वरीयता**

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the

"OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.

2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

## MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )

### Technical Specifications/तकनीकी विशिष्टियाँ

[\\* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	1 P
	<b>Rated voltage (in Volts)</b>	240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	10

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124, PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	6000

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 30 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 / 415 V, AC
	Rated Current (in Ampere)	20
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	30	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 30 pieces )**

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	1 P
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	30	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 35 pieces )**

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	2 P with 2 PP
	<b>Rated voltage (in Volts)</b>	240 / 415 V, AC
	<b>Rated Current (in Ampere)</b>	6
	<b>Instantaneous tripping current type</b>	C
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	35	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 35 pieces )****Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	2 P with 2 PP
	<b>Rated voltage (in Volts)</b>	240 V, AC
	<b>Rated Current (in Ampere)</b>	16
	<b>Instantaneous tripping current type</b>	C
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	35	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )****Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* जेम कटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)



Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	2 P with 2 PP
	<b>Rated voltage (in Volts)</b>	415 V, AC
	<b>Rated Current (in Ampere)</b>	20
	<b>Instantaneous tripping current type</b>	C
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	40	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

**Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	6000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	40	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	415 V, AC

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Rated Current (in Ampere)	40
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	40	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	2 P with 2 PP
	Rated voltage (in Volts)	240 V, AC
	Rated Current (in Ampere)	63
	Instantaneous tripping current type	C

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Rated Short circuit capacity (in Ampere)	6000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Hema O	524124, PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	3 P with 3 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	16
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )**

Technical Specifications/तकनीकी विशिष्टियाँ

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	3 P with 3 PP
	Rated voltage (in Volts)	230 / 415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	40	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )****Technical Specifications/तकनीकी विशिष्टियाँ**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	3 P with 3 PP
	<b>Rated voltage (in Volts)</b>	415 V, AC
	<b>Rated Current (in Ampere)</b>	40
	<b>Instantaneous tripping current type</b>	C
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )**

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	3 P with 3 PP
	<b>Rated voltage (in Volts)</b>	415 V, AC
	<b>Rated Current (in Ampere)</b>	63
	<b>Instantaneous tripping current type</b>	C
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 20 pieces )****Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>Conformity of the specification</b>	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	<b>No. of pole (hint: "P" - Pole, "PP" Protected Pole)</b>	4 P with 4 PP
	<b>Rated voltage (in Volts)</b>	415 V, AC
	<b>Rated Current (in Ampere)</b>	16
	<b>Instantaneous tripping current type</b>	D
	<b>Rated Short circuit capacity (in Ampere)</b>	10000
CONSTRUCTION	<b>Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs</b>	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124,PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	20	30

**MCB - Miniature Circuit - Breakers For A.C. Operation As Per IS / IEC 60898 (Part 1) ( 40 pieces )****Technical Specifications/तकनीकी विशिष्टियाँ**

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)



Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Conformity of the specification	as per IS/IEC 60898 : PART 1:2015 latest
	Product ISI Marked	Yes
RATING	No. of pole (hint: "P" - Pole, "PP" Protected Pole)	4 P with 4 PP
	Rated voltage (in Volts)	415 V, AC
	Rated Current (in Ampere)	32
	Instantaneous tripping current type	C
	Rated Short circuit capacity (in Ampere)	10000
CONSTRUCTION	Provision of steel sheet enclosure duly pretreated stove enamelled/powder coated for MCBs	Without enclosure

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Hema O	524124, PSO, SPROB STORES, SDSC SHAR, SRIHARIKOTA	40	30

**Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें**

**1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

**2. Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

**3. Warranty**

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

#### 4. **Generic**

The buyer organization is an institution eligible for concessional rates of GST as notified by the Government of India. The goods for which bids have been invited fall under classification of GST concession and the conditions for eligibility of concession are met by the institution. A certificate to this effect will be issued by Buyer to the Seller after award of the Contract. Sellers are requested to submit their bids after accounting for the Concessional rate of GST.

Applicable Concessional rate of GST :

5

%

Notification No.and date :

6/2018, dt.25-01-2018 & 25/2018, dt.31-12-2018

dated

31/12/2018

#### 5. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

Instructions to bidders:

1) Supply Condition: Item shall be delivered in working days (Monday to Friday) and during working hours from 10:00 AM to 04:00 PM) only excluding Public Holidays.

2) Delivery Locations: Items shall be delivered at SMPC-U1 Stores (SPROB STORES), Satish Dhawan Space Centre SHAR, Sriharikota.

3) Contact details: Phone Number: 08623-22-6377/6056; email id:con33.isro.ap@gembuyer.in; smpcu1-purchase@shar.gov.in

4) Please send queries/representations through GeM Bid representation provision only. Bidder may please quote GeM Bid No. & Indent No. SHSM2024004523.

## **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.

4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.**

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---